



ONSHORE PREMISES ACCESS PERMIT

HAZARD CARD: Vault(s)

SITE HAZARDS:

CONFINED SPACES:

- SUB-GROUND VAULTS

ENERGIZED ELECTRICAL EQUIPMENT (Within some vaults)

WORKING WITH LADDERS (Vault access)

SLIPPERY CONDITIONS (Vault cement flooring / wooden duck-boards)

POTENTIAL FOR REDUCED-OXYGEN ATMOSPHERE

SITE CONTROLS:

FORCE ACCESS PERMIT REQUIRED

CONTRACTOR HAZARD ASSESSMENT REQUIRED FOR, BUT NOT LIMITED TO, (As applicable):

- CONFINED SPACE ENTRY
- WORKING NEAR ENERGIZED ELECTRICAL EQUIPMENT

ANY VAULT ENTRY REQUIRES A STANDBY PERSON ON THE SURFACE, WITH VERTICAL RESCUE KIT

ANY VAULT ENTRY REQUIRES ATMOSPHERIC TESTS TO VERIFY THE VAULT IS SAFE FOR ENTRY

ALL PERSONNEL ENTERING VAULT TO WEAR VERTICAL EXTRACTION (or Fall Arrest) HARNESS

HIGH VOLTAGE RESCUE KIT REQUIRED WHEN WORKING WITH ELECTRICAL EQUIPMENT / WIRING